

116 June 20 1936

Call for survey and plat  
of Lot 6 Block 018 Lake Geneva  
Manor

for B. R. Klekamp,  
No. 140 S<sup>th</sup> Dearborn St,  
Chicago, Ill.

Iron stakes to be set at 4 corners  
2 blue prints called.

Wanted Monday June 22-1936

Dimensions of lot as per  
original plat Lake Shore Drive  
width 50' Lake Shore line 55'  
line 550 132' Line 647.132'  
Iron stakes should be found  
on 5-6 line, as this was  
re-surveyed in

	R.M. N. E. Cor
67.94	2,357.029
4.80	65.49 5980.569
4.76	65.53 5955.58
4.77	65.52 62 552
7.56	62.73

10.5' to curb line

Lateral 2 1/2' inside curb

Normal level of lake 57'

Length of lateral 7.7' add

wye to curb 10.5'

LM-38

P. 45  
16

Lower step to Flynnell Hook  
point at wye,  
Curb elevation  
elev. of walk  
elev. of ground 15' in lot

Made 7.8 ps

7-217-SK

20 1936

Survey and plat  
Block 18 Lake Geneva

R. Klekamp  
50. Dearborn St.

to be set at 4 cor-

ners called  
Sunday June 22-1936

one of lot as per  
plat Lake Shore Dr.

Lake Shore line 50'

132 Line 64-7 132

45 should be found  
in as this was

45. 112

57029 B.M. N.E. Cor

65.49 5980.5.69

65.53 59955.58

P.S.

As there has been some difficulty in locating and laying sewers to some of the properties in this subdivision due to several unavoidable conditions we give you more complete data which we hope will overcome these difficulties.

Two manholes are used in determining these data one to the North 126<sup>1/2</sup> ft. of Lot 6 block 18 and one to the south of this location App. #446 80 ft. sewer is in a straight line between manholes.

The grade of the main sewer is 1%  
The lateral is laid at 143 1/8 ft. south of North Manhole.  
There is a notch in pavement over the connection.

The lateral is laid 7.7 feet east, 6" pipe and ends 2 1/2 inside the curb. It is close to center of lot. A notch is made in top of curb and pavement.

The elevation of the pavement over the connection is 65.49  
The elevation of the invert at connection is 66.60  
The elevation of curb at end of lateral is 67.32  
The elevation of lateral at end 69.05  
The end of lateral is 2 1/2 inside of curb.

The lot at a point app. 15 ft. east of curb 59.79  
The normal level of the lake is 67.

The grade of the laterals is 3% 2%

The bench mark used is the N.E. Cor. of the lower step of the south house of the two houses to the west.

The bench mark elevation is of the bench mark 67.94' b.s.  
the city's datum plane.

Point at eye,  
Curb Elevation

7-217-SK